



**PROFILE**

**NOTES**

LARGE DOUBLE CHECK BACKFLOW ASSEMBLY (4" AND GREATER): AMES 2000SS, WATTS 709 OR FEBCO 850 MASTER SERIES.

FLANGED FITTINGS INSIDE PIT, MECHANICAL JOINT W/MEGA-LUG RETAINER GLANDS OUTSIDE OF PIT.

IN LIEU OF POURED-IN-PLACE VAULT, AN APPROVED PRE-CAST VAULT MAY BE USED.

USE BILCO OR U.S. FOUNDRY VAULT DOORS.

BACKFLOW PREVENTION DEVICES SHALL BE TESTED UPON INSTALLATION.



**W**ATER WORKS & SANITARY SEWER BOARD  
 Montgomery Alabama

**WATER DISTRIBUTION DETAILS**

TITLE: LARGE DOUBLE CHECK BACKFLOW VAULT WITH SIAMESE CONNECTION NO DETECTOR CHECK		DRAWING NO.:
DESIGNED: BS	DATE: 03/04	SCALE: NOT TO SCALE
CHECKED: HR	REVISED: 01/09	

228