



NOTES:

THE INTERCEPTOR IS SIZED SUFFICIENTLY TO SERVE A FACILITY REQUIRING UP TO A 300 GALLON DEVICE AS CALCULATED BY THE MWSSB SIZING FORM (WITH OR WITHOUT DISHWASHER PRESENT). IF NO DISHWASHER IS PRESENT, THE BOARD'S ENGINEER MAY ALLOW THE DEVICE TO SERVE IN PLACE OF A 500 GALLON DEVICE AS CALCULATED BY THE MWSSB SIZING FORM PROVIDED THERE IS NO DISHWASHER PRESENT.

WITH WRITTEN AUTHORIZATION FROM THE BOARD'S ENGINEER, TWO SMALL CONCRETE GREASE INTERCEPTORS MAY BE USED IN SERIES TO OBTAIN DESIRED VOLUME OF STORAGE (AS REQUIRED BY SIZING FORM).



WATER
WORKS & SANITARY SEWER BOARD
Montgomery Alabama

SANITARY SEWER DETAILS

TITLE: **SMALL PRECAST CONCRETE INTERCEPTOR**

DRAWING NO.:

372

DESIGNED: TL DATE: 11/13 SCALE: NOT TO SCALE
CHECKED: HR REVISED: 01/09